

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

**Supporting Information for**  
**Stochastic Generation of Multisite Streamflow for Future Water**  
**Resources Vulnerability Assessments: Application over South**  
**Korea**

Sukwang Ji<sup>1</sup> and Kuk-Hyun Ahn<sup>2</sup>

November 2021

1 Graduate Research Assistant, Department of Civil and Environmental Engineering, Kongju National University, Cheon-an, South Korea; e-mail: [wltnrhkd123@gm.kongju.ac.kr](mailto:wltnrhkd123@gm.kongju.ac.kr)

2 Assistant Professor, Department of Civil and Environmental Engineering, Kongju National University, Cheon-an, South Korea; *Corresponding author*; e-mail: [ahnkukhyun@kongju.ac.kr](mailto:ahnkukhyun@kongju.ac.kr)


**Contents of this file**

**Figures S1 to S4**  
**Text S1**

**Introduction**

This supporting information offers additional figures, tables, and descriptions to support results and conclusions of “**Stochastic Generation of Multisite Streamflow for Future Water Resources Vulnerability Assessments: Application over South Korea**”.


1



2


3 Figure S1. Time series of the assigned SOM nodes for a period of 23 years (1998 ~ 2020).

4



1  
 2 Figure S2. Comparison of observed (black) and simulated (red) cross-correlation functions of  
 3 the daily streamflow for pairs of stations among the six basins in the study area.  
 4  
 5  
 6  
 7  
 8  
 9  
 10  
 11

1



2

3

4

5

6

7

8

9

10

11

12

13

14

Figure S3. Differences between the observed and future projected median streamflows for (top) annual, (middle) flood season, and (bottom) dry season scales across the twelve study basins as well as the regional-averaged values. The simulated results are obtained by using 200 different ensemble members. The negative value demonstrates reduction in future projected streamflow.

## 1 **Text S1. Mathematical formulation of water supply systems**

2 The impact of the projected streamflow is additionally analyzed using four reservoir systems  
3 (Deacheong, Boryeong, Buan, and Hapcheon reservoirs) in South Korea. Those reservoirs  
4 (Deacheong, Boryeong, Buan, and Hapcheon reservoirs) with storage capacities of 1490 MCM,  
5 116.9 MCM, 53.0 MCM, and 790.0 MCM (1 MCM is equal to  $10^6$  m<sup>3</sup>) were constructed in  
6 1981, 1998, 1997, and 1998 to serve four main purposes: (1) flood control, (2) water supply,  
7 (3) water quality, and (4) hydropower generation, and are operated by the Korean water  
8 resources corporation (K-water). In this study, the storage (ST) at time  $t$  for each reservoir  
9 system is formulated as follows:

10

$$11 \quad ST_t = ST_{t-1} + Q_t - SP_t - CR_t \quad \text{Eq. (S1)}$$

12


13 where  $Q_t$  and  $CR_t$  are daily reservoir inflow and total controlled releases, respectively, and  
14  $SP_t$  indicates any water that spills out from the reservoir. We define that  $SP_t$  occurs only  
15 when  $S_t > S_{max}$ . Also, total controlled releases for water supply at time  $t$  are defined as  
16  $CR_t = WS_t^{MI} + WS_t^{EN} + WS_t^{IR} + WS_t^{HP}$  with the principal municipal and industrial water  
17 supply ( $WS^{MI}$ ), hydropower generation ( $WS^{HP}$ ), environmental demand ( $WS^{EN}$ ), and supply of  
18 seasonal irrigation demand ( $WS^{IR}$ ).

19

20 The four reservoirs have been operated by their own operating rules. Figure S4 shows an  
21 example of the rule curve for the Boryeong reservoir. If the reservoir level drops below the  
22 mild storage level  $SC^*$ , the water allocation for  $WS^{EN}$  is terminated until the water level rises  
23 above  $SC^*$  again. Then, if the reservoir level falls below the severe level  $SC^{**}$ , three water  
24 demands ( $WS^{EN}$ ,  $WS^{IR}$ ,  $WS^{MI}$ ) are restricted by 100%, 30%, and 10%, respectively. Here,

1 additional water restriction of 10% is conducted for  $WS^{MI}$  if the reservoir level drops below the  
2 critical storage level  $SC^{***}$ . For assessing the reservoir performance, the critical level  $SC^{***}$  is  
3 employed as a criterion in this study.

4



5

6 Figure S4 Standard operation rule curves adopted in the Boryeong reservoir.

7

8